



AGENDA

The Metropolitan Government of Nashville and Davidson County...

***Board of Plumbing Examiners and Appeals
AGENDA***

Meeting Date: Tuesday – October 2, 2018
 Place: Metro Office Building – Davidson Room – 2nd Floor
 800 2nd Avenue, South
 Time: 1:30 P.M.

PLUMBING BOARD MEMBERS	MEMBER TERM EXPIRES	MEMBER ATTENDANCE	STAFF PRESENT
Frank Sullivan, Chairman David Wilson, Vice Chairman Tommy Krantz Valarie Franklin Rhonda Weatherford John Olert Vacant Position	February 15, 2019 March 10, 2019 March 10, 2022 March 10, 2021 March 10, 2020 February 15, 2019		

AGENDA TOPICS

- I. Approval of Last Month's Minutes and Call Meeting To Order
- II. Appeal Cases
- III. Appearing Before The Board
- IV. Registrations
- V. Master Plumber Examination Approval
- VI. Journeyman Plumber Examination Approval
- VII. Other Business
- VIII. Consent Agenda
- IX. Adjournment

I. APPROVAL OF MINUTES AND CALL THE MEETING TO ORDER

Approval of the August 7, 2018 Minutes:

Changes:
Approval By:

Signature of Chairman _____

Motion:

First:
Second:
Opposed:

II. APPEAL CASES

<p><u>Appeal Case No. P-20180059957</u></p> <p style="text-align: right;">Represented by: Rob Cochran</p> <p>Site Address: 754 Lynwood Avenue</p> <p>Map/Parcel Number: 10506015800</p> <p>Appellant: Rob Cochran</p>		
<p><u>Code Provision:</u> Per IBC Table 2902.1, in a 'B' Occupancy of 1,945 square feet, one drinking fountain is required.</p> <p><u>Variance Requested:</u> Applicant would like to not install drinking fountains.</p>		
<p>Discussion: Applicant informs us that the owner states that the maximum number of occupants will be less than 15 and a sink is provided for office workers.</p>	<p>Motion: First: Second:</p>	<p>Opposed or Abstained:</p>

<p><u>Appeal Case No. P-20180059944</u></p> <p style="text-align: right;">Represented by: Rob Cochran</p> <p>Site Address: 762 E Argyle Avenue</p> <p>Map/Parcel Number: 10510005300</p> <p>Appellant: Rob Cochran</p>		
<p><u>Code Provision:</u> Per IBC Table 2902.1, in a 'B' Occupancy of 1,945 square feet, one drinking fountain is required.</p> <p><u>Variance Requested:</u> Applicant would like to not install drinking fountains.</p>		
<p>Discussion: Applicant informs us that the owner states that the maximum number of occupants will be less than 15 and a sink is provided for office workers.</p>	<p>Motion: First: Second:</p>	<p>Opposed or Abstained:</p>

III. APPEARING BEFORE THE BOARD

No Applicants – No Business

IV. REGISTRATIONS	
No Applications	

V. MASTER PLUMBER EXAMINATION APPROVAL	
No Applicants	

VI. JOURNEYMAN PLUMBER EXAMINATION APPROVAL	
No Applicants	

VII. OTHER BUSINESS	
No Business	

VIII. CONSENT AGENDA	
No Business	

IX. MOTION FOR ADJOURNMENT:	Motion: First: Second:	Opposed or Abstained:
-----------------------------	------------------------------	-----------------------