

The Metropolitan Government of Nashville and **Davidson County...**

Board of Fire and Building Code Appeals **MINTUES**

Meeting Date: Place: Time: Tuesday – February 8, 2022

Development Service Conference Center- Metro Office Building-800 2nd Ave South

9:00 A.M.

FIRE AND BUILDING	MEMBER	MEMBER	STAFF PRESENT
BOARD MEMBERS	TERM EXPIRES	ATTENDANCE	
Rich McCoy-Chairman John Finch-Vice Chairman Christopher Bainbridge Randy Clark Cal Nielson Phil Ponder Marina Ntoupi Jonathan Woodside Vacant	March 1, 2022 March 1, 2022 March 1, 2023 March1, 2025 March 1, 2022 April 1, 2025 March 1, 2022	Present Absent Present Absent Present Present Present Absent	Byron Hall Macy Amos Joe Almon Theresa Hayes

AGENDA TOPICS

- I. Call Meeting To Order
- II. **Appeal Cases**
- Other Business III.
- IV. Approval of Last Month's Minutes
- Adjournment

I. CALL THE MEETING TO ORDER	

II. APPEAL CASES

Appeal Case No. 20220004111 Site Address: 1017 A 12 th Avenue South NASHVILLE, TN 37203	Re	Represented by: Remick Moore Jayme Jacobsor				
Map/Parcel Number: 105013T00100CO Appellant: Jayme Jacobson Parcel Owner: Vacation World Inc. & KJ Texas Properties, LLC						
Code Provision : IBC 1006.3.3 Single exits. A single exit or access to a single exit shall be permitted from any story or occupied roof where one of the following conditions exist: #5. Individual single-story or multistory dwelling units shall be permitted to have a single exit or access to a single exit from the dwelling unit provided that both of the following criteria are met: 5.1 The dwelling unit complies with Section 1006.2.1 as a space with one means of egress. 1006.2.1 Egress based on occupant load and common path of egress travel distance. Two exits or exit access doorways from any space shall be provided where the design occupant load or the common path of egress travel distance exceeds the values listed in Table 1006.2.1 Table 1006.2.1 states for R-2 occupancy the maximum common path of egress travel distance in a space with a Sprinkler System is 125 feet.						
Applicant Appeals: Applicant appeals the maximum travel distance in a 4-story R-2 dwelling unit with a stated travel path of 176.1'						
Discussion:		Motion: Deny First: P. Ponder Second: C. Bainbridge		Approved / Denied: <u>Denied</u> 5-0		
III. OTHER BUSINESS:						
Approval of Minutes:						
Changes: Approval By:						
Signature of Chairman						

IV. MOTION FOR ADJOURNMENT: