

The Metropolitan Government of Nashville and Davidson County...

Board of Fire and Building Code Appeals MINUTES

Meeting Date: Place: Time: Tuesday - March 8, 2022

Development Service Conference Center- Metro Office Building-800 2nd Ave South

9:00 A.M.

FIRE AND BUILDING	MEMBER	MEMBER	STAFF PRESENT
BOARD MEMBERS	TERM EXPIRES	ATTENDANCE	
Rich McCoy-Chairman John Finch-Vice Chairman Christopher Bainbridge Randy Clark Cal Nielson Phil Ponder Marina Ntoupi Jonathan Woodside Vacant	March 1, 2022 March 1, 2022 March 1, 2023 March 1, 2025 March 1, 2023 April 1, 2025 March 1, 2022	Present Absent Present Absent Absent Present Present Present Present	Tara Ladd Joe Almon Wade Hill Byron Hall Theresa Hayes

AGENDA TOPICS

- I. Call Meeting To Order
- II. Appeal Cases
- III. Other Business
- IV. Approval of Last Month's Minutes
- V. Adjournment

I. CALL THE MEETING TO ORDER	

II. APPEAL CASES

Appeal Case No. 20220008136

Site Address: 2117 SADLER AVENUE NASHVILLE, TN 37210

Map/Parcel Number: 106133K00200CO **Appellant: Mr. Quantavious Poole**Parcel Owner: Lomah Investments, LLC

Represented by: Quantavious Poole Derrick Sandoval

<u>Code Provision</u>: To appeal the following code item addressing fire department access - 2018 NFPA 1 section 18.2.3.3. Multiple Access Roads. More than one fire department access road shall be provided when it is determined by the AHJ that access by a single road could be impaired by vehicle congestion, condition of terrain, climate conditions, or other factors that could limit access.

Applicant Appeals: Appellant requests variance for existing property conditions

Discussion:	Motion:	Approve	Approved / Denied: Approved
	First: Second:	Bainbridge Ponder	5/0 With Stipulation- Must Sprinkler Both Units

Appeal Case No. 20220012548

Site Address: 820 4TH Avenue N

Nashville, TN 37219

Map/Parcel Number: 08213040600

Appellant: Ross Kirby

Parcel Owner: PR Germantown, LLC

Represented by: Ross Kirby Brittany Sanders

Code Provision: IBC 202 Definitions. High-rise Building. A building with an occupied floor located more than 75 feet above the lowest level of fire department vehicle access.

Applicant Appeals: Applicant appeals the determination of a high-rise structure and the resultant requirements of IBC section 404 for such high-rise structures, based on the presence of Mezzanines and private roof terraces in individual residential units that are located more than 75 feet above street level.

Discussion:	Motion: Deny	Approved / Denied:
	First: Ntoupi Second: Bainbridge	Denied 5-0

Appeal Case No. 20220012718 Represented by: Site Address: 127 Rosa L Parks Blvd. Nashville, TN 37203 Map/Parcel Number: 09305404000 Appellant: Travis Parker Parcel Owner: Christ Episcopal Church, Wardens & Vestry Code Provision: NFPA 1 Fire Code 2018 Edition, Annex F Fire Fighter Breathing-Air Replenishment Systems. F.1 General. Where required by the AHJ, fire fighter breathing-air replenishment systems shall comply with Appendix F of the uniform Plumbing Code. Applicant Appeals: Applicant seeks relief from this requirement			
Discussion:	Motion:	Approved / Denied:	
	First: Second:	Withdrawn	
Appeal Case No. 20220012748 Site Address: 127 Rosa L Parks Blvd. Nashville, TN 37203 Map/Parcel Number: 09305404000 Appellant: Travis Parker Parcel Owner: Christ Episcopal Church, Wardens & Vestry			
 <u>Code Provision</u>: 2018 IBC Section 1025 Luminous Egress Path Markings, 1025.2 Markings Within Exit Components. Egress path markings shall be provided in interior exit stairways, interior exit ramps and exit passageways, in accordance with Sections 1025.2.1 through 1025.2.6. <u>Applicant Appeals</u>: Applicant seeks relief from this requirement 			
Discussion:	Motion: Approve First: Bainbridge Second: Ponder	Approved / Denied: Approved 5-0 With Stipulation — Exit Stairways Only	

III. OTHER BUSINESS:		
Approval of Minutes: Changes: Approval By: Signature of Chairman		
IV. MOTION FOR ADJOURNMENT:		