



# AGENDA

## The Metropolitan Government of Nashville and Davidson County

### Board of Mechanical, Plumbing, and Electrical Examiners and Appeals

Meeting Date: Tuesday – July 18, 2023  
 Place: Davidson Room – 800 2<sup>nd</sup> Avenue, South – Second Floor  
 Time: 1:30 P.M.

PLUMBING BOARD MEMBERS	MEMBER TERM EXPIRES	MEMBER ATTENDANCE	STAFF PRESENT
Michael Porter, Chairman Brian Yunker, Vice Chairman Terry Atwood Thomas Greer Weston Iler Tommy Krantz Morgan Miller-Wallace Anthony Pezzi James Lasater	September 21, 2023 September 21, 2024 September 21, 2023 September 21, 2023 September 21, 2025 September 21, 2023 September 21, 2025 September 21, 2024 August 1, 2025		

#### AGENDA TOPICS

- I. Public Comment Period
- II. Approval of Last Month’s Minutes and Call Meeting To Order
- III. Appeal Cases
- IV. Appearing Before The Board
- V. Registration Approvals
- VI. Examination Approvals
- VII. Property Owner Permits
- VIII. Other Business
- IX. Consent Agenda
- X. Adjournment

#### I. PUBLIC COMMENT PERIOD

Persons who write their names on the sign-up sheet provided at the meeting will be allowed to comment on matters that are germane to items on the Agenda. To provide comment, you must sign up prior to the beginning of the meeting.

II. APPROVAL OF MINUTES AND CALL THE MEETING TO ORDER	
Approval of the December 20, 2022 Minutes:  Changes: Approval By:  Signature of Chairman _____	Motion:  First: Second: Opposed:

III. APPEAL CASES		
<p><b><u>Appeal Case No. 20230044498</u></b></p> <p style="text-align: right;">Represented by: Heather Parks</p> <p>Site Address: 2737 Couchville Pike</p> <p>Map/Parcel Number: 12100015200</p> <p>Appellant: Graybar Electric</p>		
<p><u>Code Provision:</u> NEC 230.2 Number of Services - A building or other structure served shall be supplied by only one service unless permitted in 230.2(A) through (D). For the purpose of 230.40, Exception No. 2 only, underground sets of conductors, 1/0 AWG and larger, running to the same location and connected together at their supply end but not connected together at their load end shall be considered to be supplying one service.</p> <p>(A) Special Conditions (B) Special Occupancies. By special permission, additional services shall be permitted for either of the following: (1) Multiple-occupancy buildings where there is no available space for service equipment accessible to all occupants (2) A single building or other structure sufficiently large to make two or more services necessary (C) Capacity Requirements. Additional services shall be permitted under any of the following: (1) Where the capacity requirements are in excess of 2000 amperes at a supply voltage of 1000 volts or less (2) Where the load requirements of a single-phase installation are greater than the serving agency normally supplies through one service (3) By special permission (D) Different Characteristics (E) Identification</p> <p><u>Variance Requested:</u> Appellant appeals the requirement for only a single service based on NEC 230.2 (B)-(2) and (C)-(3)</p>		
Discussion:	Motion:  First: Second:	Opposed or Abstained:

IV. APPEARING BEFORE THE BOARD

No Applicants – No Business

V. REGISTRATION APPROVALS

No Applications

VI. EXAMINATION APPROVALS

No Applicants

VII. PROPERTY OWNER PERMITS

No Applicants

VIII. OTHER BUSINESS

No Other Business

IX. CONSENT AGENDA

No Business

X. MOTION FOR ADJOURNMENT:

Motion:  
First:  
Second:

Opposed or Abstained: